


Fire Door Inspections - Commercial Properties



- The frame should be to the same standard as the door
- Door closer
- There should be a minimum of three hinges per door
- Vision panel should be fire resisting glazing
- Door handles and locks should be tested as part of a door set
- Intumescent strip and cold smoke seal to resist the passage of smoke and fire

Are you complying with the Regulatory Reform (Fire Safety) Order (RRO) 2005 (as amended)?

Six monthly checks are required to identify issues early and to ensure all of the fire doors function correctly.

Fireline Engineers as trained BRE fire door inspectors can do these for you.

We can visit your property on a six-monthly basis, complete the checks and provide you with a comprehensive report ensuring that your property is compliant and advise you of any issues.



An image of a fire door having done its job

We only carry out intrusive Fire Door Inspections following initial inspection and consultation with the customer.

What we will check:

- Door identification
- Frame & leaf
- Gaps & seals
- Hinges & closers
- Locks, handles and vision panels
- Signage

Our report will include an ID number for each door as well as an image. If you have a floor plan this can be used as part of the report to plot each door location.

Please note, you have an obligation to carry out more frequent checks for doors experiencing high traffic



- We can carry out a full fire door inspection and integrate it within your fire risk assessment document.
- The initial fire door inspection is more comprehensive, involving measurements and conformity checks.